



Product Service

Attestation of Conformity

No. N8A 107768 0014 Rev. 01

Holder of Certificate: **Ningbo Raytech New Energy Materials Co., Ltd.**
No.18, Qiyuan Road
Hangzhou Bay New Area
315300 Ningbo
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 882162030202

Date, 2021-01-28

(Xinlian LUO)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 107768 0014 Rev. 01

Model(s):

1500VDC modules

BPDMJ72H-XXXWEF(XXX=430W-455W, in step of 5)

BPDMJ60H-XXXWEF(XXX=360W-380W, in step of 5)

BPDMJ60H-XXXWE(XXX=360W-380W, in step of 5)

BPDMJ72H-XXXTEF(XXX=430W-440W, in step of 5)

BPDMJ60H-XXXTEF(XXX=360W-365W, in step of 5)

BPDMJ60H-XXXTE(XXX=360W-365W, in step of 5)

BPDMJ36H-XXXTE(XXX=215W-230W, in step of 5)

DMJ72H-XXXWEF(XXX=430W-450W, in step of 5)

DMJ60H-XXXWEF(XXX=360W-375W, in step of 5)

DMJ60H-XXXWE(XXX=360W-375W, in step of 5)

DMJ72H-XXXTEF(XXX=425W-435W, in step of 5)

DMJ60H-XXXTEF(XXX=355W-360W, in step of 5)

DMJ60H-XXXTE(XXX=355W-360W, in step of 5)

1000VDC modules

BPDMJ72HS-XXXWEF(XXX=430W-455W, in step of 5)

BPDMJ60HS-XXXWEF(XXX=360W-380W, in step of 5)

BPDMJ60HS-XXXWE(XXX=360W-380W, in step of 5)

BPDMJ72HS-XXXTEF(XXX=430W-440W, in step of 5)

BPDMJ60HS-XXXTEF(XXX=360W-365W, in step of 5)

BPDMJ60HS-XXXTE(XXX=360W-365W, in step of 5)

BPDMJ36HS-XXXTE(XXX=215W-230W, in step of 5)

DMJ72HS-XXXWEF(XXX=430W-450W, in step of 5)

DMJ60HS-XXXWEF(XXX=360W-375W, in step of 5)

DMJ60HS-XXXWE(XXX=360W-375W, in step of 5)

DMJ72HS-XXXTEF(XXX=425W-435W, in step of 5)

DMJ60HS-XXXTEF(XXX=355W-360W, in step of 5)

DMJ60HS-XXXTE(XXX=355W-360W, in step of 5)

XXX is standing for rated output power at STC

Parameters:

Construction: Frameless or Framed, with Junction box, Cable and Connectors

Test Laboratory: Changzhou HuaYang Inspection and Testing Technology Co., Ltd.(NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China)

Safety Class: Class II

Maximum System Voltage: 1000VDC or 1500VDC

Fire Safety Class: Class C according to UL790

Tested

according to:

EN IEC 61730-1:2018

EN IEC 61730-2:2018

EN IEC 61730-1:2018/AC:2018-06

EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.